



NOTES:

1. Contractor to place meter boxes in non-traffic area only.
2. Meter must be level across meter connections.
3. Substitution requires approval by Town Engineer.
4. See detail 519.01, sheet 1 of 2 for meter installation detail.

METERED SERVICES	SIZE "F" / MATERIAL (COPPER) (I.D.)
11-20	2" TYPE K HARD DRAWN
5-10	2" TYPE K HARD DRAWN
4	1" TYPE K SOFT DRAWN
2	3/4" TYPE K SOFT DRAWN
TAPPING	SEE DETAIL 519.01 & 519.03, SHEET 2, AS APPLICABLE.



TOWN of CLAYTON
USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

STANDARD GANG METER ASSEMBLY

SCALE: Not To Scale	DETAIL # 2 519.02
REVISION DATE: July, 2010	SHEET #: 1 of 1