

General Information			Cause				Customers	
Date	P/U	Feeder / Address	Description	Time Off	Time On	Mins	# Out	Cust Minutes
10/15/2015	P	EAST / Astor, Tulip, & Hwy 70	Replaced poles	8:00am	4:15pm	495	10	4,950
10/15/2015	U	WEST / W. Main & Atkinson Street	Damaged cut-out on Pole #F631	8:20am	9:25am	65	150	9,750
10/20/2015	U	EAST / 105 Neuse Ridge Drive	Contractor cut cable	3:00pm	4:45pm	105	1	105
10/21/2015	P	EAST / Astor, Tulip, & Hwy 70	Reconductoring poles	8:00am	2:40pm	400	10	4,000
10/22/2015	U	SOUTH & CENTRAL / Fayetteville St.	Terminator on exit cable went bad in substation	10:30am	11:00am	30	500	15,000
10/26/2015	U	SOUTH / 506 Woodbriar Road	Bad Underground	3:20pm	4:30pm	70	1	70
10/28/2015	U	WEST / 1404 Old US 70	Tree rubbed the triplex in two	2:43pm	3:30pm	47	3	141
10/28/2015	U	CENTRAL / 117 E. Horne Street	Old copper wire to house went bad, Pole F306	10:28pm	1:00am	152	1	152
10/31/2015	U	SOUTH / 1104 Cardinal Drive	Blown fuse due to squirrel on line	9:30am	10:30am	60	15	900

P=Planned

U=Unplanned